

RFQ 5FY19 QUESTION

RFQ 5FY19 Question 5:

1. Is the RFQ just for supply only or construction/erection as well?
 2. The scope sheet calls for 4” fiberglass in the roof. Is this 4” fiberglass insulation?
 3. The scope sheet calls for high panel clips. Are you asking for a standing seam roof?
- **Supply only for the Building.**
 - **Yes 4 inch insulation.**
 - **Yes standing seam roof panels.**