

RFQ 1FY20 QUESTION(S)

RFQ 1FY20 Question 11:

Requesting clarification on the following items:

Kennels:

1. For the kennels plans it is showing 3/4" plywood on all the wall sections at the bottom of the trusses. Am I to figure this throughout the whole building? Also the wall types call for metal furring but the wall sections call for 1x pt furring. Should I just assume it is to be wood furring since the interior walls are wood? **Yes, plywood throughout and wood furring**
2. For the k-9 Kennel, there is no detail for the interior block walls located by the kennel bank. Can I assume they are continuous 10' tall with one row of u-block at the top? **Yes, poured solid every 5 foot**
3. The plan does not show any footings for the block walls mentioned in question #1. Please provide a detail for this. **Footing will be 16x24 for block wall**
4. The plan calls for 8 columns at sheet A1.1, however, there is no detail for these. Please provide a detail including dimensions and steel reinforcement if they are concrete. **Architect will provide this information and will be posted ASAP**
5. The plan does not show what supports the block on top of the west and east walls with the chain link fence. Are they tie beams? Please clarify with details. **Figure using tie beams every 12 feet with lintels**
6. On Sheet A5.1 detail 2, it shows walls going all the way up to 23'-4". I assumed 10' walls for the entire building. Please clarify what is the correct height for this. **10' walls**
7. On some sheets the plan calls for metal furring and on others it calls for wood furring in the same area. Please clarify on correct material. **Wood furring**
8. Some of the wall details on sheet A1.2 call for a typical substrate for interior walls. What does this mean? **Architect will provide this information and will be posted ASAP**

Indoor training:

9. On details 4/A1.0 for Indoor Trailing Facility and detail 1/A1.0 for the Indoor Training Facility Warehouse, shows the footer. Are these the footings for the Metal building column? If yes, can you please clarify the details of the footing and its location on the plan? **Architect will provide this information and will be posted ASAP**