

## RFQ 1FY20 QUESTION(S)

### RFQ 1FY20 Question 7:

Requesting clarification on the following items:

1. The plans call for a 50'-0" by 80'-0" building, but the specifications call for a 50'-0" by 70'-0" building. Which is correct?
  - **Go by the plans not the spec sheet.**
  
2. Do the 2" Insulated Wall Panels run around the entire building? If so, is there no additional wall insulation to be installed between the Insulated Panels and the PEMB Framing, such as Vinyl-Backed Fiberglass Insulation?
  - **Panel goes around entire building, no extra insulation.**
  
3. Are the Parapet Walls referenced in the specifications at the "High" Endwall actually Gable Endwall Panels?
  - **Yes, High end is the Gable end wall.**
  
4. The electrical schedules don't match on A2.0 and E4.0. Fixtures and counts are different on all three drawings. Please take a look at the E lighting schedules and please confirm which one to be followed.
  - **Use the electrical that will allow for the most fixture counts to be safe.**