

RFQ 1FY20 QUESTION(S)

RFQ 1FY20 Question 8:

Please see below RFI for Indoor Open training facility warehouse building:

1. On the sheet A1.0 there is a storage area with the staircase please clarify if it is a mezzanine. And what type of partition wall is between open training area and storage area? Also, please provide the interior elevations and interior wall heights.
 - Bid it as Mezzanine. Bid the wall heights at 16 feet on sidewalls and 20 foot to gable top.
 - The wall heights for the storage room is a standard 8ft wall heights.