

RFP 1FY26- Vendor Questions

1. There appears to be discrepancies between the bid set phasing (A-E on page C3.1) and areas labeled in the Attachment A/Bid Form 1A-1E. For example, the 1E/Part E General site hardness improvements on the bid form, are labeled with Phase A in the bid set. Will you please clarify? **The request to rectify has been made to Coastal Designs.**
2. Is the Parking lot to the south of the CREMP bldg. to be bid in the General hardening 1E or CREMP Civil 1A on the bid form? **Bid as CREMP civil**
3. Can an updated attachment A be provided Civil to reflect changes and inclusions to the Exhibit? **The request to rectify has been made to Coastal Designs.**
4. The existing 2-story Cyber bldg. shows a parking lot to be constructed in the bid set. However, the attachment A Exhibit does not include this area. Will you confirm what pay item this is to be included in? **The parking lots to the East and South of the Cyber building are existing but will need to tie in seamlessly to the new construction.**
5. The entrance road (Charles Bo-Harrison Way) to the site is shown in the general site hardening but it appears that no work is to be performed for the first 200+/- ft. Can you please confirm if this is correct? **Correct, but the new road will need to tie in seamlessly to the existing.**
6. Is the asphalt parking lot located at the Existing Forensics, Explorer Post, Training Center to be Milled and paved? If not, can you clarify what work is to be completed in this parking lot other than curb rework, striping, and wheel stops? Also, for clarification which bid item to include in. **The existing portion of the parking lot will need to be repaved, new curbs, striping and wheel stops.**
7. Section 4.2, Item B, indicates we are to submit Statement of Qualifications SF 330. This is typically a form used by Engineers/Architects. Can we submit AIA 305 instead, which is a typical Contractor qualifications statement?
 - a. Additionally, the link provided does not work.
Yes, it does look like SF 330 applies to Architects and engineers, AIA 305 -2020 would be better.
8. Section 4.2, Item D, indicates to use Section H of SF330 for Approach to Project. Can we submit Project Approach on our letterhead? **Letterhead would be acceptable.**
9. Please confirm electronic submittals via Euna/Demandstar are still acceptable (since bid date was changed). **Yes, we are still accepting submittals are being accepted via Euna/Demandstar.**

10. Please confirm bid opening date/time – could the bid opening be virtual?

We are currently working on confirming the new bid opening date and time.