


RESPONSE TO BID RFI's

PROJECT:	Pasco Sheriff - Wellness/MPEH Center	RFI NO.	Bid RFI Log
OWNER:	Pasco County Sheriff's Office	DATE OF ISSUANCE:	02-06-26 Rev 1: 03-05-26
TO:	Jasmin Ortiz-Olson Purchasing Manager Pasco Sheriff's Office	ARCHITECT:	Furr, Wegman & Banks Architects, P.A. 625 E. Orange Street Lakeland, FL 33801
ARCHITECT'S PROJECT NO.: 25-14			

RESPONSE:

***Owner is responsible for distribution to all qualified bidders**

ARCHITECTURAL:	
1.	Page A-141 indicates a motorized door, but the specs indicate a manual operated door. Shall we price motorized or manual?
RESPONSE:	Price and provide a motorized operated door.
2.	Door hardware schedule is not present on the project documents, it only makes references to the hardware groups on page A141. Can you provide the door hardware schedule?
RESPONSE:	Please refer to written specification booklet with complete door hardware sets. In addition, this new information was provided by the Owner: Keyways for the doors for the gym shall be Schlage SC4 6 pin. At bathrooms use Schlage punch code door locks SC1 5 pin.
3.	Please confirm if the anchor bolt are going to be by Pre-fab metal bldg. Manufacturer. SD1 Hairpin details shows them by BLD Manufacturer and they typically do not provide anchor bolts.
RESPONSE:	The anchor bolt count, layout and diameter are to be specified by the metal building engineering. Material should also be specified by metal building engineering, however our structural engineer has F1554 Gr 36 steel grade as a minimum. The embedment detail to be followed is our structural engineer. Procurement, or the actual threaded rod itself, shall be supplied by the GC.

Submitted by: 
Cindy R. Green, AIA